

Table 1 - Water Sample Results Lead - Location

Project Name: Herkimer Central School District

B&L Project No.: 899.115.001

Sample Date: 3/2/2017 - Elementary

Location	Sample ID	Approx. Time (hh:mm)	Sample Analysis	Results (µg/l)	NYS SED/EPA Action Level* (µg/l)	Comments
Kitchen Prep Sink	1A	07:00	Lead	7.7000	15.000	First draw
			Lead		15.000	Second draw
			Lead		15.000	Third Draw
Kitchen Prep 3 Pot Sink Right Faucet	2A	07:02	Lead	4.7000	15.000	First draw
	2B	07:03	Lead	1.2000	15.000	Second draw
			Lead		15.000	Third Draw
Kitchen Prep Right Pot Filler	3A	07:05	Lead	3.5000	15.000	First draw
	3B	07:05	Lead	0.9500	15.000	Second draw
			Lead		15.000	Third Draw
Room 2A Hand Sink	4A	07:11	Lead	5.4000	15.000	First draw
			Lead		15.000	Second draw
			Lead		15.000	Third Draw
Room 2A Above Ceiling	5A	07:13	Lead	3.3000	15.000	First draw
			Lead		15.000	Second draw
			Lead		15.000	Third Draw

< - less than detectable level

* - NYS SED/EPA Action Level for Schools

ug/l - micrograms per liter of water

bold - at or exceeds an action level