

Table 1 - Water Sample Results Lead - Location

Project Name: Herkimer Central School District

B&L Project No.: 899.115.001

Sample Date: 3/2/2017 - High School

Location	Sample ID	Approx. Time (hh:mm)	Sample Analysis	Results (µg/l)	NYS SED/EPA Action Level* (µg/l)	Comments
Kitchen Hand Sink	1A	05:05	Lead	4.2000	15.000	First draw
	1B	05:06	Lead	0.5700	15.000	Second draw
				Lead		15.000
Kitchen Right Pot Filler	2A	05:07	Lead	3.1000	15.000	First draw
	2B	05:08	Lead	0.5200	15.000	Second draw
				Lead		15.000
Room 123 Teacher's Sink	3A	05:15	Lead	3.2000	15.000	First draw
	3B	05:16	Lead	0.7700	15.000	Second draw
				Lead		15.000
Room 123 Middle Island Front Sink	4A	05:17	Lead	5.5000	15.000	First draw
	4B	05:18	Lead	0.5400	15.000	Second draw
				Lead		15.000
Room 123 Middle Island Back Sink	5A	05:19	Lead	2.9000	15.000	First draw
	5B	05:20	Lead	0.4200	15.000	Second draw
				Lead		15.000
Room 123 Middle Island Left Sink	6A	05:21	Lead	7.0000	15.000	First draw
	6B	05:22	Lead	0.4800	15.000	Second draw
				Lead		15.000
Room 123 Middle Island Right Sink	7A	05:23	Lead	2.5000	15.000	First draw
	7B	05:24	Lead	0.3700	15.000	Second draw
				Lead		15.000
Room 123 Back Island Left Sink	8A	05:24	Lead	5.8000	15.000	First draw
	8B	05:25	Lead	0.3500	15.000	Second draw
				Lead		15.000
Room 123 Back Island Right Sink	9A	05:25	Lead	2.2000	15.000	First draw
	9B	05:26	Lead	0.3300	15.000	Second draw
				Lead		15.000

< - less than detectable level

* - NYS SED/EPA Action Level for Schools

ug/l - micrograms per liter of water

bold - at or exceeds an action level

Table 1 - Water Sample Results Lead - Location

Project Name: Herkimer Central School District

B&L Project No.: 899.115.001

Sample Date: 3/2/2017 - High School

Location	Sample ID	Approx. Time (hh:mm)	Sample Analysis	Results (µg/l)	NYS SED/EPA Action Level* (µg/l)	Comments
Room 123 Back Corner Sink	10A	05:27	Lead	2.8000	15.000	First draw
	10B	05:28	Lead	0.3500	15.000	Second draw
			Lead		15.000	Third Draw
Room 123 Right Counter Left Sink	11A	05:29	Lead	4.9000	15.000	First draw
	11B	05:30	Lead	0.2500	15.000	Second draw
			Lead		15.000	Third Draw
Room 123 Right Counter Right Sink	12A	05:31	Lead	3.2000	15.000	First draw
	12B	05:32	Lead	0.3000	15.000	Second draw
			Lead		15.000	Third Draw
Room 121 Teacher's Sink	13A	05:35	Lead	2.1000	15.000	First draw
	13B	05:36	Lead	0.4500	15.000	Second draw
			Lead		15.000	Third Draw
Room 121 Front Right Sink	14A	05:36	Lead	4.6000	15.000	First draw
	14B	05:37	Lead	0.4700	15.000	Second draw
			Lead		15.000	Third Draw
Room 121 Back Right Sink	15A	05:38	Lead	8.4000	15.000	First draw
	15B	05:39	Lead	0.5800	15.000	Second draw
			Lead		15.000	Third Draw
Room 121 Back Center Sink	16A	05:40	Lead	3.0000	15.000	First draw
	16B	05:41	Lead	0.3500	15.000	Second draw
			Lead		15.000	Third Draw
Room 121 Back Left Sink	17A	05:42	Lead	4.4000	15.000	First draw
	17B	05:43	Lead	0.2800	15.000	Second draw
			Lead		15.000	Third Draw
Room 121 Front Right Sink	18A	05:43	Lead	3.5000	15.000	First draw
	18B	05:44	Lead	0.2700	15.000	Second draw
			Lead		15.000	Third Draw

< - less than detectable level

* - NYS SED/EPA Action Level for Schools

ug/l - micrograms per liter of water

bold - at or exceeds an action level

Table 1 - Water Sample Results Lead - Location

Project Name: Herkimer Central School District

B&L Project No.: 899.115.001

Sample Date: 3/2/2017 - High School

Location	Sample ID	Approx. Time (hh:mm)	Sample Analysis	Results (µg/l)	NYS SED/EPA Action Level* (µg/l)	Comments
Room 120 Teacher's Sink	19A	05:46	Lead	7.1000	15.000	First draw
	19B	05:47	Lead	0.3500	15.000	Second draw
			Lead		15.000	Third Draw
Room 120 Front Right Sink	20A	05:48	Lead	3.4000	15.000	First draw
	20B	05:49	Lead	0.4400	15.000	Second draw
			Lead		15.000	Third Draw
Room 120 Back Right Sink	21A	05:49	Lead	3.4000	15.000	First draw
	21B	05:50	Lead	0.3600	15.000	Second draw
			Lead		15.000	Third Draw
Room 120 Back Center Sink	22A	05:51	Lead	2.6000	15.000	First draw
	22B	05:52	Lead	0.3500	15.000	Second draw
			Lead		15.000	Third Draw
Room 120 Back Left Sink	23A	05:53	Lead	3.4000	15.000	First draw
	23B	05:54	Lead	0.3800	15.000	Second draw
			Lead		15.000	Third Draw
Room 120 Front Left Sink	24A	05:55	Lead	3.6000	15.000	First draw
	24B	05:56	Lead	0.2400	15.000	Second draw
			Lead		15.000	Third Draw
Room 120/118 Chemical Storage Sink	25A	05:59	Lead	1.9000	15.000	First draw
	25B	06:00	Lead	0.7000	15.000	Second draw
			Lead		15.000	Third Draw
Room 118 Front Right Bay Left Sink	26A	06:02	Lead	4.8000	15.000	First draw
	26B	06:03	Lead	0.6700	15.000	Second draw
			Lead		15.000	Third Draw
Room 118 Front Left Bay Right Sink	27A	06:04	Lead	2.7000	15.000	First draw
	27B	06:04	Lead	0.9600	15.000	Second draw
			Lead		15.000	Third Draw

< - less than detectable level

* - NYS SED/EPA Action Level for Schools

ug/l - micrograms per liter of water

bold - at or exceeds an action level

Table 1 - Water Sample Results Lead - Location

Project Name: Herkimer Central School District

B&L Project No.: 899.115.001

Sample Date: 3/2/2017 - High School

Location	Sample ID	Approx. Time (hh:mm)	Sample Analysis	Results (µg/l)	NYS SED/EPA Action Level* (µg/l)	Comments	
Room 118 Back Left Bay Left Sink	28A	06:06	Lead	2.5000	15.000	First draw	
	28B	06:06	Lead	1.6000	15.000	Second draw	
				Lead		15.000	Third Draw
Room 118 Back Center Bay Left Sink	29A	06:08	Lead	3.9000	15.000	First draw	
	29B	06:09	Lead	0.5200	15.000	Second draw	
				Lead		15.000	Third Draw
Room 118 Back Center Bay Right Sink	30A	06:09	Lead	132.0000	15.000	First draw	
	30B	06:10	Lead	2.8000	15.000	Second draw	
				Lead		15.000	Third Draw
Room 118 Back Right Bay Left Sink	31A	06:11	Lead	129.0000	15.000	First draw	
	31B	06:12	Lead	1.3000	15.000	Second draw	
				Lead		15.000	Third Draw
Room 118 Left Wall Rear Sink	32A	06:13	Lead	7.4000	15.000	First draw	
	32B	06:14	Lead	1.5000	15.000	Second draw	
				Lead		15.000	Third Draw
Room 229 Teacher's Sink	33A	06:18	Lead	7.9000	15.000	First draw	
	33B	06:19	Lead	0.6900	15.000	Second draw	
				Lead		15.000	Third Draw
Room 229 Front Left Sink	34A	06:20	Lead	2.3000	15.000	First draw	
	34B	06:21	Lead	0.4900	15.000	Second draw	
				Lead		15.000	Third Draw
Room 229 Back Right Sink	35A	06:22	Lead	2.3000	15.000	First draw	
	35B	06:23	Lead	0.5400	15.000	Second draw	
				Lead		15.000	Third Draw
Room 229 Front Right Sink	36A	06:23	Lead	42.9000	15.000	First draw	
	36B	06:24	Lead	0.6400	15.000	Second draw	
				Lead		15.000	Third Draw

< - less than detectable level

* - NYS SED/EPA Action Level for Schools

ug/l - micrograms per liter of water

bold - at or exceeds an action level

Table 1 - Water Sample Results Lead - Location

Project Name: Herkimer Central School District

B&L Project No.: 899.115.001

Sample Date: 3/2/2017 - High School

Location	Sample ID	Approx. Time (hh:mm)	Sample Analysis	Results (µg/l)	NYS SED/EPA Action Level* (µg/l)	Comments	
Room 231 Teacher's Sink	37A	06:26	Lead	18.7000	15.000	First draw	
	37B	06:27	Lead	1.6000	15.000	Second draw	
			Lead		15.000	Third Draw	
Room 231 Back Left Sink	38A	06:28	Lead	1.8000	15.000	First draw	
	38B	06:28	Lead	2.9000	15.000	Second draw	
			Lead		15.000	Third Draw	
Room 231 Back Right Sink	39A	06:29	Lead	4.7000	15.000	First draw	
	39B	06:30	Lead	0.4400	15.000	Second draw	
			Lead		15.000	Third Draw	
Room 178 Girls Coach's Bathroom Sink	40A	06:37	Lead	226.0000	15.000	First draw	Rusty, discolored
	40B	06:38	Lead	61.6000	15.000	Second draw	
			Lead		15.000	Third Draw	
Girls Locker Rm. Right Sink	41A	06:39	Lead	224.0000	15.000	First draw	
	41B	06:40	Lead	108.0000	15.000	Second draw	
			Lead		15.000	Third Draw	

< - less than detectable level

* - NYS SED/EPA Action Level for Schools

ug/l - micrograms per liter of water

bold - at or exceeds an action level