

LEAD TESTING OF DRINKING WATER IN SCHOOLS

HERKIMER CSD - MIDDLE-HIGH SCHOOL

TESTING BY PACE ANALYTICAL SERVICES, LLC

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
HS-4	12/11/2024 07:00	1/3/2025 15:54	70328698001	Lead	<1.0	5	ug/L
HS-5	12/11/2024 07:00	1/3/2025 15:58	70328698002	Lead	<1.0	5	ug/L
HS-5A	12/11/2024 07:00	1/3/2025 16:21	70328698003	Lead	<1.0	5	ug/L
HS-19	12/11/2024 06:58	1/3/2025 16:23	70328698004	Lead	<1.0	5	ug/L
HS-20	12/11/2024 06:58	1/3/2025 16:25	70328698005	Lead	<1.0	5	ug/L
HS-25	12/11/2024 06:52	1/3/2025 16:26	70328698006	Lead	1.7	5	ug/L
HS-26	12/11/2024 06:52	1/3/2025 16:28	70328698007	Lead	1.1	5	ug/L
HS-27	12/11/2024 06:52	1/3/2025 16:30	70328698008	Lead	2.1	5	ug/L
HS-28	12/11/2024 06:52	1/3/2025 16:31	70328698009	Lead	1.7	5	ug/L
HS-29	12/11/2024 06:52	1/3/2025 16:33	70328698010	Lead	1.6	5	ug/L
HS-39	12/11/2024 07:06	1/3/2025 16:34	70328698011	Lead	<1.0	5	ug/L
HS-40	12/11/2024 07:06	1/3/2025 16:39	70328698012	Lead	<1.0	5	ug/L
HS-54	12/11/2024 06:50	1/3/2025 16:41	70328698013	Lead	<1.0	5	ug/L
HS-95	12/11/2024 06:46	1/3/2025 16:42	70328698014	Lead	<1.0	5	ug/L
HS-98	12/11/2024 06:44	1/3/2025 16:44	70328698015	Lead	1.8	5	ug/L
HS-109	12/11/2024 06:24	1/3/2025 16:45	70328698016	Lead	<1.0	5	ug/L
HS-110	12/11/2024 06:24	1/3/2025 16:47	70328698017	Lead	9.0	5	ug/L
HS-112	12/11/2024 06:37	1/3/2025 16:49	70328698018	Lead	<1.0	5	ug/L
HS-113	12/11/2024 06:37	1/3/2025 16:50	70328698019	Lead	<1.0	5	ug/L
HS-124	12/11/2024 06:39	1/3/2025 16:52	70328698020	Lead	<1.0	5	ug/L
HS-125	12/11/2024 06:39	1/3/2025 16:59	70328698021	Lead	<1.0	5	ug/L
HS-137	12/11/2024 06:27	1/3/2025 17:04	70328698022	Lead	<1.0	5	ug/L
HS-138	12/11/2024 06:27	1/3/2025 17:08	70328698023	Lead	<1.0	5	ug/L
HS-143	12/11/2024 06:20	1/3/2025 17:10	70328698024	Lead	<1.0	5	ug/L
HS-144	12/11/2024 06:20	1/3/2025 17:12	70328698025	Lead	<1.0	5	ug/L
HS-149	12/11/2024 06:10	1/3/2025 17:16	70328698026	Lead	7.1	5	ug/L
HS-150	12/11/2024 06:10	1/3/2025 17:18	70328698027	Lead	3.5	5	ug/L
HS-151	12/11/2024 06:12	1/3/2025 17:19	70328698028	Lead	2.7	5	ug/L
HS-152	12/11/2024 06:12	1/3/2025 17:21	70328698029	Lead	11.7	5	ug/L
HS-153	12/11/2024 06:13	1/3/2025 17:23	70328698030	Lead	1.7	5	ug/L
HS-154	12/11/2024 06:13	1/3/2025 17:24	70328698031	Lead	3.7	5	ug/L
HS-160	12/11/2024 06:13	1/3/2025 17:26	70328698032	Lead	10.5	5	ug/L
HS-161	12/11/2024 06:13	1/3/2025 17:27	70328698033	Lead	6.3	5	ug/L
HS-162	12/11/2024 06:13	1/3/2025 17:29	70328698034	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb

LEAD TESTING OF DRINKING WATER IN SCHOOLS

HERKIMER CSD - ELEMENTARY SCHOOL

TESTING BY PACE ANALYTICAL SERVICES, LLC

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
ES3	12/11/2024 07:43	1/3/2025 09:02	70328701001	Lead	<1.0	5	ug/L
ES4	12/11/2024 07:43	1/3/2025 09:08	70328701002	Lead	<1.0	5	ug/L
ES5	12/11/2024 07:38	1/3/2025 09:12	70328701003	Lead	2.8	5	ug/L
ES8	12/11/2024 07:37	1/3/2025 09:17	70328701004	Lead	13.9	5	ug/L
ES9	12/11/2024 07:37	1/3/2025 09:19	70328701005	Lead	49.3	5	ug/L
ES10	12/11/2024 07:41	1/3/2025 09:20	70328701006	Lead	6.8	5	ug/L
ES12	12/11/2024 07:44	1/3/2025 09:22	70328701007	Lead	1.1	5	ug/L
ES14	12/11/2024 07:45	1/3/2025 09:23	70328701008	Lead	2.4	5	ug/L
ES15	12/11/2024 07:46	1/3/2025 09:25	70328701009	Lead	1.4	5	ug/L
ES17	12/11/2024 07:59	1/3/2025 09:26	70328701010	Lead	20.9	5	ug/L
ES18	12/11/2024 07:59	1/3/2025 09:28	70328701011	Lead	3.3	5	ug/L
ES 20	12/11/2024 08:36	1/3/2025 09:30	70328701012	Lead	3.2	5	ug/L
ES 21	12/11/2024 08:36	1/3/2025 09:31	70328701013	Lead	27.7	5	ug/L
ES 23	12/11/2024 08:29	1/3/2025 09:36	70328701014	Lead	22.6	5	ug/L
ES 24	12/11/2024 08:29	1/3/2025 09:37	70328701015	Lead	4.9	5	ug/L
ES 26	12/11/2024 08:31	1/3/2025 09:39	70328701016	Lead	2.0	5	ug/L
ES 27	12/11/2024 08:31	1/3/2025 09:40	70328701017	Lead	1.5	5	ug/L
ES 32	12/11/2024 07:50	1/3/2025 09:42	70328701018	Lead	1.7	5	ug/L
ES 40	12/11/2024 07:49	1/3/2025 09:44	70328701019	Lead	<1.0	5	ug/L
ES 41	12/11/2024 07:49	1/3/2025 09:45	70328701020	Lead	<1.0	5	ug/L
ES 44	12/11/2024 07:26	1/3/2025 09:50	70328701021	Lead	1.1	5	ug/L
ES 45	12/11/2024 07:26	1/3/2025 09:57	70328701022	Lead	3.2	5	ug/L
ES 46	12/11/2024 07:26	1/3/2025 10:02	70328701023	Lead	1.4	5	ug/L
ES 47	12/11/2024 07:26	1/3/2025 10:03	70328701024	Lead	3.3	5	ug/L
ES 48	12/11/2024 07:26	1/3/2025 10:05	70328701025	Lead	3.8	5	ug/L
ES 49	12/11/2024 07:26	1/3/2025 10:07	70328701026	Lead	1.7	5	ug/L
ES 50	12/11/2024 07:26	1/3/2025 10:08	70328701027	Lead	4.5	5	ug/L
ES 51	12/11/2024 07:26	1/3/2025 10:13	70328701028	Lead	2.2	5	ug/L
ES-69	12/12/2024 07:20	1/3/2025 10:14	70328701029	Lead	2.5	5	ug/L
ES-70	12/12/2024 07:20	1/3/2025 17:47	70328701030	Lead	102	5	ug/L
ES-72	12/12/2024 08:03	1/3/2025 10:16	70328701031	Lead	2.7	5	ug/L
ES-73	12/12/2024 08:03	1/3/2025 10:17	70328701032	Lead	12.7	5	ug/L
ES-74	12/12/2024 07:22	1/3/2025 10:19	70328701033	Lead	6.5	5	ug/L
ES-75	12/12/2024 07:22	1/3/2025 10:21	70328701034	Lead	18.5	5	ug/L
ES-76	12/12/2024 08:01	1/3/2025 10:22	70328701035	Lead	3.0	5	ug/L
ES-77	12/12/2024 08:01	1/3/2025 10:24	70328701036	Lead	35.0	5	ug/L
ES-78	12/12/2024 07:24	1/3/2025 10:25	70328701037	Lead	40.1	5	ug/L
ES-79	12/12/2024 07:24	1/3/2025 10:27	70328701038	Lead	65.7	5	ug/L
ES-80	12/12/2024 07:59	1/3/2025 10:31	70328701039	Lead	1.8	5	ug/L
ES-81	12/12/2024 07:59	1/3/2025 10:33	70328701040	Lead	11.4	5	ug/L
ES-83	12/12/2024 07:25	1/3/2025 10:35	70328701041	Lead	34.2	5	ug/L
ES-84	12/12/2024 07:25	1/3/2025 10:39	70328701042	Lead	33.6	5	ug/L
ES-85	12/12/2024 07:57	1/3/2025 10:44	70328701043	Lead	3.0	5	ug/L
ES-86	12/12/2024 07:57	1/3/2025 10:51	70328701044	Lead	19.0	5	ug/L

ES-87	12/12/2024 07:27	1/3/2025 10:53	70328701045	Lead	3.7	5	ug/L
ES-88	12/12/2024 07:27	1/3/2025 10:54	70328701046	Lead	15.1	5	ug/L
ES-89	12/12/2024 07:55	1/3/2025 10:56	70328701047	Lead	2.9	5	ug/L
ES-90	12/12/2024 07:55	1/3/2025 10:57	70328701048	Lead	36.0	5	ug/L
ES-91	12/12/2024 07:30	1/3/2025 10:59	70328701049	Lead	3.2	5	ug/L
ES-92	12/12/2024 07:30	1/3/2025 11:00	70328701050	Lead	17.7	5	ug/L
ES-94	12/12/2024 07:52	1/3/2025 11:02	70328701051	Lead	3.6	5	ug/L
ES-95	12/12/2024 07:52	1/3/2025 11:04	70328701052	Lead	42.8	5	ug/L
ES-96	12/12/2024 07:32	1/3/2025 12:13	70328701053	Lead	3.2	5	ug/L
ES-97	12/12/2024 07:32	1/3/2025 12:15	70328701054	Lead	5.2	5	ug/L
ES-98	12/12/2024 07:47	1/3/2025 12:16	70328701055	Lead	3.0	5	ug/L
ES-100	12/12/2024 07:37	1/3/2025 12:18	70328701056	Lead	1.6	5	ug/L
ES-101	12/12/2024 07:37	1/3/2025 12:20	70328701057	Lead	26.7	5	ug/L
ES-102	12/12/2024 07:40	1/3/2025 12:21	70328701058	Lead	1.2	5	ug/L
ES-103	12/12/2024 07:40	1/3/2025 12:23	70328701059	Lead	10.0	5	ug/L
ES-104	12/12/2024 07:36	1/3/2025 12:24	70328701060	Lead	1.6	5	ug/L
ES-105	12/12/2024 07:36	1/3/2025 12:26	70328701061	Lead	12.2	5	ug/L
ES-111	12/11/2024 07:51	1/3/2025 12:33	70328701062	Lead	3.6	5	ug/L
ES-112	12/11/2024 07:51	1/3/2025 12:38	70328701063	Lead	2.2	5	ug/L
ES-116	12/11/2024 08:05	1/3/2025 12:42	70328701064	Lead	9.6	5	ug/L
ES-117	12/11/2024 08:05	1/3/2025 12:44	70328701065	Lead	39.3	5	ug/L
ES-119	12/11/2024 08:08	1/3/2025 12:45	70328701066	Lead	1.3	5	ug/L
ES-120	12/11/2024 08:08	1/3/2025 12:50	70328701067	Lead	3.7	5	ug/L
ES-122	12/12/2024 07:01	1/3/2025 12:52	70328701068	Lead	2.2	5	ug/L
ES-123	12/12/2024 07:01	1/3/2025 12:53	70328701069	Lead	73.3	5	ug/L
ES-125	12/11/2024 08:10	1/3/2025 12:55	70328701070	Lead	7.4	5	ug/L
ES-126	12/11/2024 08:10	1/3/2025 12:56	70328701071	Lead	1.3	5	ug/L
ES-128	12/12/2024 07:03	1/3/2025 12:58	70328701072	Lead	3.5	5	ug/L
ES-129	12/12/2024 07:03	1/3/2025 12:59	70328701073	Lead	23.5	5	ug/L
ES-131	12/11/2024 08:12	1/3/2025 13:01	70328701074	Lead	1.4	5	ug/L
ES-133	12/11/2024 08:12	1/3/2025 13:03	70328701075	Lead	2.4	5	ug/L
ES-134	12/12/2024 07:05	1/3/2025 13:20	70328701076	Lead	1.1	5	ug/L
ES-135	12/12/2024 07:05	1/3/2025 13:35	70328701077	Lead	7.7	5	ug/L
ES-137	12/11/2024 08:14	1/3/2025 13:39	70328701078	Lead	1.6	5	ug/L
ES-138	12/11/2024 08:14	1/3/2025 13:41	70328701079	Lead	9.7	5	ug/L
ES-140	12/12/2024 07:07	1/3/2025 13:42	70328701080	Lead	1.3	5	ug/L
ES-141	12/12/2024 07:07	1/3/2025 13:44	70328701081	Lead	17.4	5	ug/L
ES-143	12/11/2024 08:17	1/3/2025 13:45	70328701082	Lead	1.5	5	ug/L
ES-144	12/11/2024 08:17	1/3/2025 13:47	70328701083	Lead	9.9	5	ug/L
ES-146	12/12/2024 07:09	1/3/2025 13:49	70328701084	Lead	2.1	5	ug/L
ES-147	12/12/2024 07:09	1/3/2025 13:53	70328701085	Lead	10.0	5	ug/L
ES-149	12/11/2024 08:19	1/3/2025 13:55	70328701086	Lead	1.4	5	ug/L
ES-150	12/11/2024 08:19	1/3/2025 13:56	70328701087	Lead	40.3	5	ug/L
ES-152	12/12/2024 07:11	1/3/2025 13:58	70328701088	Lead	1.5	5	ug/L
ES-153	12/12/2024 07:11	1/3/2025 13:59	70328701089	Lead	12.2	5	ug/L
ES-155	12/11/2024 08:22	1/3/2025 14:01	70328701090	Lead	1.2	5	ug/L
ES-156	12/11/2024 08:22	1/3/2025 14:03	70328701091	Lead	10.6	5	ug/L
ES-158	12/12/2024 07:13	1/3/2025 14:04	70328701092	Lead	1.5	5	ug/L
ES-159	12/12/2024 07:13	1/3/2025 14:06	70328701093	Lead	7.5	5	ug/L
ES-161	12/11/2024 08:24	1/3/2025 14:07	70328701094	Lead	118	5	ug/L

ES-162	12/11/2024 08:24	1/3/2025 14:12	70328701095	Lead	3.7	5	ug/L
ES-171	12/12/2024 07:49	1/3/2025 14:42	70328701096	Lead	1.3	5	ug/L
ES-172	12/12/2024 07:49	1/3/2025 14:43	70328701097	Lead	23.6	5	ug/L
ES-173	12/12/2024 07:44	1/3/2025 14:45	70328701098	Lead	1.2	5	ug/L
ES-174	12/12/2024 07:44	1/3/2025 14:49	70328701099	Lead	26.1	5	ug/L
ES-176	12/12/2024 07:46	1/3/2025 14:51	70328701100	Lead	2.4	5	ug/L
ES-177	12/12/2024 07:46	1/3/2025 14:52	70328701101	Lead	29.8	5	ug/L
ES-178	12/12/2024 07:17	1/3/2025 14:54	70328701102	Lead	<1.0	5	ug/L
ES-179	12/12/2024 07:17	1/3/2025 14:56	70328701103	Lead	<1.0	5	ug/L
ES-180	12/12/2024 07:34	1/3/2025 14:57	70328701104	Lead	<1.0	5	ug/L
ES-181	12/12/2024 07:34	1/3/2025 14:59	70328701105	Lead	<1.0	5	ug/L
ES-194	12/12/2024 08:07	1/3/2025 15:03	70328701106	Lead	222	5	ug/L
ES-195	12/12/2024 07:34	1/3/2025 15:11	70328701107	Lead	<1.0	5	ug/L
ES-196	12/12/2024 07:34	1/3/2025 15:16	70328701108	Lead	<1.0	5	ug/L
ES-197	12/12/2024 08:01	1/3/2025 15:17	70328701109	Lead	<1.0	5	ug/L
ES-198	12/12/2024 08:01	1/3/2025 15:19	70328701110	Lead	<1.0	5	ug/L
ES-199	12/12/2024 08:35	1/3/2025 15:21	70328701111	Lead	<1.0	5	ug/L
ES-200	12/12/2024 08:35	1/3/2025 15:22	70328701112	Lead	<1.0	5	ug/L
ES 118	12/11/2024 08:06	1/3/2025 15:27	70328701113	Lead	4.7	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb